

**O‘ZBEKISTON RESPUBLIKASI
OLIIY TA‘LIM, FAN VA INNOVATSIYALAR VAZIRLIGI
ANDIJON MASHINASOZLIK INSTITUTI**

**MASHINASOZLIK
ILMIY-TEXNIKA JURNALI**

**МИНИСТЕРСТВО ВЫСШЕГО ОБРАЗОВАНИЯ, НАУКИ И ИННОВАЦИЙ
РЕСПУБЛИКИ УЗБЕКИСТАН
АНДИЖАНСКИЙ МАШИНОСТРОИТЕЛЬНЫЙ ИНСТИТУТ**

**НАУЧНО-ТЕХНИЧЕСКИЙ ЖУРНАЛ
МАШИНОСТРОЕНИЕ**

**MINISTRY OF HIGHER EDUCATION, SCIENCE AND INNOVATIONS REPUBLIC
OF UZBEKISTAN
ANDIJAN MACHINE-BUILDING INSTITUTE
SCIENTIFIC AND TECHNICAL JOURNAL
MACHINE BUILDING**

O‘zbekiston Respublikasi Vazirlar mahkamasi huzuridagi Oliy attestatsiya komissiyasi (OAK) Rayosatining 2021-yil 30-dekabrda 310/10-son qarori bilan Andijon mashinasozlik institutining “Mashinasozlik” ilmiy-texnika jurnali “TEXNIKA” va “IQTISODIYOT” fanlari bo‘yicha falsafa doktori (PhD) va fan doktori (DSc) ilmiy darajasiga talabgorlarning dissertatsiya ishlari yuzasidan asosiy ilmiy natijalarini chop etish tavsiya etilgan ilmiy nashrlar ro‘yxatiga kiritilgan.

Ushbu jurnalda chop etilgan materiallar tahririyatning yozma ruxsatisiz to‘liq yoki qisman chop etilishi mumkin emas. Tahririyatning fikri mualliflar fikri bilan har doim mos tushmasligi mumkin. Ilmiy-texnika jurnalida yozilgan materiallarning haqqoniyligi uchun maqolaning mualliflari mas’uldirlar.

MASHINASOZLIK
ILMIY-TEXNIKA JURNALI

Bosh muharrir:

U.M.Turdialiyev – texnika fanlari doktori, k.i.x.

Mas’ul muharrir:

U.A.Madrahimov – iqtisodiyot fanlari doktori, professor.

T A H R I R H A Y ’ A T I

Turdialiyev Umid Muxtaraliyevich – texnika fanlari doktori, katta ilmiy xodim (AndMI);
Madrahimov Ulug’bek Abdixalilovich – iqtisodiyot fanlari doktori, professor (AndMI);
Negmatov Soyibjon Sodiqovich – texnika fanlari doktori, professor O’ZRFA akademigi (TDTU);
Abralov Maxmud Abralovich – texnika fanlari doktori, professor (TDTU);
Dunyashin Nikolay Sergeevich – texnika fanlari doktori, professor (TDTU);
Norxudjayev Fayzulla Ramazanovich – texnika fanlari doktori, professor (TDTU);
Pirmatov Nurali Berdiyarovich – texnika fanlari doktori, professor (TDTU);
Salixanova Dilnoza Saidakbarovna – texnika fanlari doktori, professor (O’ZRFA UNKI);
Siddikov Ilxomjon Xakimovich – texnika fanlari doktori, professor (TIQXMMI);
Fayzimatov Shuhrat Numanovich – texnika fanlari doktori, professor (FarPI);
Xakimov Ortiqali Sharipovich – texnika fanlari doktori, professor (Standartlashtirish, sertifikatlashtirish va texnik jihatdan tartibga solish ilmiy-tadqiqot instituti);
Xo’jayev Ismatillo Qo’shiyevich – texnika fanlari doktori, professor (Mexanika instituti);
Ipatov Oleg Sergeevich – professor (Sankt-Peterburg politexnika universiteti, Rossiya);
Naumkin Nikolay Ivanovich - p.f.d., t.f.n., professor. (Mordov milliy tadqiqot davlat universiteti, Rossiya);
Aliyev Suxrob Rayimjonovich – fizika-matematika fanlari bo’yicha falsafa doktori (PhD), dotsent (AndMI);
Shen Zhili – professor (Shimoliy Xitoy texnologiyalar universiteti, Xitoy);
Hu Fuwen – professor (Shimoliy Xitoy texnologiyalar universiteti, Xitoy);
Won Cholyeon – professor (Janubiy Koreya Milliy tadqiqotlar fondi, Janubiy Koreya);
Celio Pina – professor (Setubal politexnika universiteti, Portugaliya);
Ricardo Baptista – professor (Setubal politexnika universiteti, Portugaliya);
Rui Vilela – professor (Setubal politexnika universiteti, Portugaliya);
Dmitriy Albertovich Konovalov - t.f.n., professor (Voronej davlat texnika universiteti);
Мухаметшин Вячеслав Шарифуллович – директор Института нефти и газа федерального государственного бюджетного образовательного учреждения высшего образования «Уфимский государственный нефтяной технический университет» (филиал в г.Октябрьском), доктор геологоминералогических наук, профессор.
Nimchik Aleksey Grigorevich – kimyo fanlari doktori, professor (TDTU Olmaliq filiali)
Muftaydinov Qiyomiddin – iqtisodiyot fanlari doktori, professor (AndMI);
Zokirov Saidfozil – i.f.d., (Prognozlashtirish va makroiqtisodiy tadqiqotlar instituti);
Orazimbetova Gulistan Jaksilikovna - t.f.d., dotsent (AndMI)
Jo’raxonov Muzaffar Eskanderovich – iqtisodiyot fanlari bo’yicha falsafa doktori (AndMI);
Ermatov Akmaljon – iqtisodiyot fanlari nomzodi, dotsent (AndMI);
Qosimov Karimjon – texnika fanlari doktori, professor (AndMI);
Yusupova Malikaxon – iqtisodiyot fanlari nomzodi, dotsent (AndMI);
Akbarov Xatamjon Ulmasaliyevich – texnika fanlari nomzodi, dotsent (AndMI);
Mirzayev Otabek Abdiraximovich – texnika fanlari bo’yicha falsafa doktori (PhD), dotsent (AndMI);
Soxibova Zarnigor Mutalibjon qizi – fizika-matematika fanlari bo’yicha falsafa doktori (PhD), (AndMI);
Raxmonov O’ktam Kamolovich – texnika fanlari bo’yicha falsafa doktori (PhD), (TDTU, Olmaliq filiali);
Xoshimov Xalimjon Xamidjanovich – texnika fanlari bo’yicha falsafa doktori (PhD), (AndMI).
Kuluyev Ruslan Raisovich - texnika fanlari bo’yicha falsafa doktori (PhD), (TDTU).

Texnik muharrir:

B.Iminov, M.Kenjayeveva – Andijon mashinasozlik instituti nashriyoti.

Tahririyat manzili: Andijon shahar, Bobur shox ko’cha, 56-uy. **Tel:** +998 74-224-70-88 (1016)

Veb sayt: www.andmiedu.uz

e-mail: andmi.jurnal@mail.ru

“Mashinasozlik” ilmiy-texnika jurnali O‘zbekiston Respublikasi Axborot va ommaviy kommunikatsiyalar agentligining 2020 yil 28- fevraldagi 04-53-raqamli guvohnomasiga binoan chop etiladi.

MASHINASOZLIK VA MASHINASHUNOSLIK. MASHINASOZLIKDA MATERIALLARGA ISHLOV BERISH. METALLURGIYA. AVIASIYA TEXNIKASI	
Payvandlash uchun grafitli elektrodlar haqida umumiy tushuncha <i>Tursunov A.S, Turdialiyev U.M.</i>	6
Junni o‘simlik aralashmalaridan ajratish kuchi va uzayishini aniqlash <i>Djurayev A., Elmonov S.M.</i>	10
Arrali jin mashinasi operatorini xavfsizligini ta‘minlovchi optik to‘siq sensorini modellashtirish <i>Azizov Sh.M., Usmanov O.N.</i>	16
Мобильная опреснительная установка <i>Турсунов М.Н., Сабиров Х., Ахтамов Т.З., Насимов У.М., Жабборов Ш. А.</i>	26
Разработка технологии изготовления корпуса подшипника роликов ленточного конвейера <i>Хамраев Б.Д., Хусанов Я., Шакулов Б.К., Усманов Ш.Н., Далиев Ш.Л.</i>	31
Sanoat changlarini yong‘in xavfini baholash tizimlari tahlili <i>Qobulova N.J.</i>	36
Vintli konveyer mashina agregati yuritgich-reduktori va vint valini harakat qonunlarini aniqlash <i>Teshaboyev O.A.</i>	42
Zichlashtirish mashinalari texnologik jarayonini tadqiq etishda fizik modellashtirishning mohiyati <i>Xankelov T.Q., Kayumov A.D., Xudaykulov R.M., Komilov S.I.</i>	48
Разработка облегченной конструкции пыльного цилиндра джина <i>Мирзамудов А.Ш.</i>	54
Flyus qatlami ostida payvandlangan vagon – sisternalarni payvand chokining mexanik xossalarni tadqiqot qilish <i>Qosimov K.Z., Begmatov D.K.</i>	60
Respublikamiz sharoitida mavjud tuproqqa ishlov beruvchi mashinalar ishchi organlari va hududlardagi tuproqlarning turlari va ulardan foydalanishning tadqiqi <i>Qosimov K.Z., Maxmudov I.R., Ro‘ziyev A.Y.</i>	66
Термическая обработка порошкообразных наплавочных износостойких литых деталей машин <i>Тилабов Б.К., Олимжонов Р.З.</i>	71
ENERGETIKA VA ELEKTROTEXNIKA. QISHLOQ XO‘JALIGI ISHLAB CHIQRISHINI ELEKTRLASHTIRISH TEXNOLOGIYASI. ELEKTRONIKA	
Criteria for the existence of established modes of power systems <i>Davirov A.K., Mamadiev H.N.</i>	77
Yog‘-moy korxonalarida mahsulot birligiga to‘g‘ri keladigan elektr energiya solishtirma sarfiga turli omillarning ta‘sirini regression tahlili <i>Latipov S.T.</i>	84
Comsol multiphysicsda biomassa piroliz jarayonining kinetikasini modellashtirish <i>Gulom N.U., Sayyora G.M.</i>	93
Elektr energiyasini sanoat va ishlab chiqarish korxonalarida iste‘mol qilish qonuniyatlarini tahlil qilish <i>Shirinov S.G‘., Olimov J.S.</i>	99

ENERGETIKA VA ELEKTROTEXNIKA. QISHLOQ XO‘JALIGI ISHLAB CHIQRISHINI ELEKTRLASHTIRISH TEXNOLOGIYASI. ELEKTRONIKA

Davirov Alisher Kuvondik ugli, PhD
National Research University - Tashkent Institute of Irrigation
and Agricultural Mechanization Engineers, senior teacher
sheralisher171@gmail.com, +998900029171

Mamadiev Humoyun Norkul ogli
National Research University - Tashkent Institute of Irrigation
and Agricultural Mechanization Engineers, PhD student
xumoyunmamadiyev@gmail.com

CRITERIA FOR THE EXISTENCE OF ESTABLISHED MODES OF POWER SYSTEMS

O‘RNATILGAN ENERGIYA TIZIMLARI REJIMLARINING MAVJUDLIG MEZONLARI

КРИТЕРИИ СУЩЕСТВОВАНИЯ УСТАНОВИВШИХСЯ РЕЖИМОВ ЭНЕРГОСИСТЕМ

ANNOTATION

The article considers the criteria for the existence of established modes of power systems. Nonlinear nodal equations of steady-state modes are presented, which have many solutions or do not have any physically realizable solutions. Criteria for the existence of solutions based on derivatives of power losses depending on the parameters of the power system modes are given. Shown: equivalent circuit of the electrical system of the South-Western MEN (MAIN ELECTRIC NETWORKS); results of calculations of steady-state modes of the electrical system at weighted values of node 12. The maximum normal modes of electrical systems for the power of nodes determined by the criteria are set $\frac{\partial \Delta P_c}{\partial \Pi_i} = \infty$.

ANNOTATSIYA

Maqolada barqarorlashgan holatning mavjudlik mezonlari ko‘rib chiqiladi. Barqarorlashgan holatning elektr tizimidagi quvvat isrofining xosilasiga bog‘liq bo‘lgan nochiziqli tenglamalar sistemasi keltirilgan bo‘lib, keltirilgan tugun tenglamalari sistemasi bir nechta yechimga ega bo‘lishi yoki birorta ham yechimga ega bo‘lmasligi mumkin. Ko‘rsatilgan: Elektr tizimning janubiy-g‘arbiy qismining ekvivalent sxemasi keltirilgan bo‘lib, 12-tugun uchun elektr tizimining barqarorlashgan holati xisoblash natijalari keltirilgan. Elektr tizimining quyidagi qiymat bilan aniqlanadigan quvvat bo‘yicha chegaraviy holati o‘rnatilgan $\frac{\partial \Delta P_c}{\partial \Pi_i} = \infty$.

АННОТАЦИЯ

В статье рассматриваются критерии существования установившихся режимов энергосистем. Представлены нелинейные узловые уравнения установившихся режимов, имеющие множество решений или не имеющие ни одного физически реализуемого решения. Приведены критерии существования решений, основанных на

производных потерях мощности в зависимости от параметров режимов энергосистемы. Показаны: эквивалентная схема электрической системы Юго-Западных МЭС; результаты расчетов установившихся режимов электрической системы при утяжеленных значениях узла 12. Установлены предельные нормальные режимы электрических систем по мощности узлов, определенные по критерию

$$\frac{\partial \Delta P_c}{\partial \Pi_i} = \infty, .$$

Key words: Energy, active loss, criteria, voltage

Tayanch so'zlar: Energiya, isroflar, mezonlar, kuchlanish

Ключевые слова: Энергия, активные потери, напряжение.

1. Introduction

A system of equations of a steady-state electrical system due to non-linearity with respect to the desired variables can formally have a set of solutions or not have any physically realizable solutions. Since, in general, the solution of nonlinear nodal equations (NE) for a complex electrical system can only be obtained iteratively, it is necessary to solve the problem of the relationship between the convergence of the process and the existence of the solution. Indeed, if the iterative process does not converge when calculating a certain mode, the solution can sometimes be obtained by improving the initial approximation, correcting the course of the process (using accelerating coefficients, introducing an additional parameter, etc.), or using another method. There is also a problem of stability of the obtained solution [1-2]. Thus, it is necessary to solve the problem of the relationship between the properties of nonlinear equations and real modes, i.e., the adequacy of the properties of the steady-state mode of the real electric power system and its accepted mathematical model.

Determining the steady-state mode, the limit for any of its parameters (power or voltage modulus of individual nodes, power flow, etc.) is a common task in practice. In general, this problem can be solved through a series of calculations of steady-state modes with their "weights". In this case, the options and trajectories of weighting the mode from the source to the limit are determined by the nature of the problem being solved.

The limit on convergence of the iterative process under weighting corresponds to the limit mode only under the assumption of convergence of the applied algorithm to physically implemented solutions in a simply connected region containing the source and limit modes.

Since the loss of convergence of the iterative process cannot serve as a criterion for the impracticability of the assumed mode without additional conditions, it is necessary to have another, physically justified criterion. The most suitable system function for the formulation of the mode limit criterion is the total power loss function, which depends on all parameters of the Electric power system mode.

2. Method

Based on computational and experimental studies, the following position is established: the steady state mode is the limit for the deviation of any independent parameter $\Pi_i \in P_i, Q_i$, if small changes in this parameter cause infinitely large changes in the total loss of active power in the system.

$$\frac{\partial \Delta P_c}{\partial \Pi_i} \rightarrow \infty \Leftrightarrow \Pi_i \rightarrow \Pi_{i\text{lim}} \quad (1)$$

Since the dependence of active power losses on the mode parameters is explicitly expressed in terms of the matrix of nodal resistances, we get the expression (1) in the form of the Jacobian NE. (nodal equations)

$$\Delta S_c = -\hat{I}_0 U_0 - \sum_{i=1}^N S_i = (\hat{Y}_{0s} U_0 - \hat{B}\hat{I}) U_0 - \sum_{i=1}^N S_i \quad (2)$$

From (2) for the active loss component, we have

$$\Delta P_c = g_{0s} U_0^2 + U_0 \sum_{i=1}^N [B \odot_i (P_i U'_i + Q_i U''_i) - B''_i (P_i U''_i - Q_i U'_i)] / U_i^2 - \sum_{i=1}^n P_i \quad (3)$$

The expression of a partial derivative of a function over an independent variable $\Pi_i \in P_i, Q_i$ has the form

$$\frac{\partial \Delta P_c}{\partial \Pi_i} = \frac{\partial \Delta \bar{P}_c}{\partial \Pi_i} + \sum_{k=1}^N \left(\frac{\partial \Delta P_c}{\partial U'_k} \cdot \frac{\partial U'_k}{\partial \Pi_i} + \frac{\partial \Delta P_c}{\partial U''_k} \cdot \frac{\partial U''_k}{\partial \Pi_i} \right) \quad (4)$$

где

$$\frac{\partial \Delta P_c}{\partial U'_k} = \frac{U_0}{U_k^4} \left\{ B'_k \left[P_k (U_k'^2 - U_k''^2) - 2Q_k U'_k U''_k \right] + B''_k \left[Q_k (U_k''^2 - U_k'^2) + 2P_k U'_k U''_k \right] \right\} \quad (5)$$

$$\frac{\partial \Delta P_c}{\partial U''_k} = \frac{U_0}{U_k^4} \left\{ B'_k \left[Q_k (U_k'^2 - U_k''^2) - 2P_k U'_k U''_k \right] - B''_k \left[P_k (U_k''^2 - U_k'^2) + 2Q_k U'_k U''_k \right] \right\} \quad (6)$$

Expressions of partial derivatives $\frac{\partial U'_k}{\partial \Pi_i}$ и $\frac{\partial U''_k}{\partial \Pi_i}$ we get from the nodal equations system by writing them in the form of a stress balance in matrix form:

$$\begin{vmatrix} W'(U) \\ W''(U) \end{vmatrix} = \begin{vmatrix} U' \\ U'' \end{vmatrix} - \begin{vmatrix} A' \\ A'' \end{vmatrix} U_0 - \begin{vmatrix} \text{Re}(Z\hat{S}) & -\text{Im}(Z\hat{S}) \\ \text{Im}(Z\hat{S}) & \text{Re}(Z\hat{S}) \end{vmatrix} \cdot \begin{vmatrix} (U'_i / U_i^2) \\ (U''_i / U_i^2) \end{vmatrix} \quad (7)$$

where $\text{Re}(Z\hat{S}), \text{Im}(Z\hat{S})$ - square matrices of order $2N$, which elements are

$$\text{Re}(Z\hat{S}) = R_{ik} P_k + X_{ik} Q_k, \quad \text{Im}(Z\hat{S}) = X_{ik} P_k - R_{ik} Q_k.$$

Differentiating the system of implicit functions of $2N$ dependent variables (7) by some independent variable $\Pi_i \in P_i, Q_i$, we have

$$\begin{vmatrix} \frac{\partial W'}{\partial U'} & \frac{\partial W'}{\partial U''} \\ \frac{\partial W''}{\partial U'} & \frac{\partial W''}{\partial U''} \end{vmatrix} \cdot \begin{vmatrix} \frac{\partial U'}{\partial \Pi_i} \\ \frac{\partial U''}{\partial \Pi_i} \end{vmatrix} = - \begin{vmatrix} \frac{\partial W'}{\partial \Pi_i} \\ \frac{\partial W''}{\partial \Pi_i} \end{vmatrix} \quad (8)$$

Then the matrix-column of the desired partial derivatives is defined as

$$\begin{bmatrix} \frac{\partial U'}{\partial \Pi_i} \\ \frac{\partial U''}{\partial \Pi_i} \end{bmatrix} = -[J(\mathbf{U})]^{-1} \cdot \begin{bmatrix} \frac{\partial W'}{\partial \Pi_i} \\ \frac{\partial W''}{\partial \Pi_i} \end{bmatrix}, \quad (9)$$

where is the Jacobian NE (nodal equations) in the form of stress balance

$$J(\mathbf{U}) = \begin{bmatrix} \frac{\partial W'}{\partial U'} & \frac{\partial W'}{\partial U''} \\ \frac{\partial W''}{\partial U'} & \frac{\partial W''}{\partial U''} \end{bmatrix} \quad (10)$$

it is obtained by differentiating the equations (7). We find them element by element ($k \neq i$):

$$\begin{aligned} \frac{\partial W'_i}{\partial U'_k} &= [\operatorname{Re}(Z_{ik}\hat{S}_k)(U_k'^2 - U_k''^2) + 2\operatorname{Im}(Z_{ik}\hat{S}_k)U'_k U_k''] / U_k^4, \\ \frac{\partial W'_i}{\partial U''_k} &= -[\operatorname{Re}(Z_{ik}\hat{S}_k)2U'_k U_k'' + \operatorname{Im}(Z_{ik}\hat{S}_k)(U_k'^2 - U_k''^2)] / U_k^4, \\ \frac{\partial W''_i}{\partial U'_k} &= [-\operatorname{Re}(Z_{ik}\hat{S}_k)2U'_k U_k'' + \operatorname{Im}(Z_{ik}\hat{S}_k)(U_k'^2 - U_k''^2)] / U_k^4, \\ \frac{\partial W''_i}{\partial U''_k} &= [\operatorname{Re}(Z_{ik}\hat{S}_k)(U_k'^2 - U_k''^2) - 2\operatorname{Im}(Z_{ik}\hat{S}_k)U'_k U_k''] / U_k^4, \end{aligned} \quad (11)$$

Besides:

$$\frac{\partial W'_i}{\partial U'_i} = 1 + [\operatorname{Re}(Z_{ii}\hat{S}_i)(U_i'^2 - U_i''^2) + 2\operatorname{Im}(Z_{ii}\hat{S}_i)U'_i U_i''] / U_i^4 \quad (12)$$

From (4) and (9) we obtain an expression of the derivative of the active power loss function in the form of the NE Jacobian in the form of a voltage balance:

$$\frac{\partial \Delta P_c}{\partial \Pi_i} = \frac{\partial \Delta \bar{P}_c}{\partial \Pi_i} - \left[\frac{\partial \Delta P_c}{\partial U'}, \frac{\partial \Delta P_c}{\partial U''} \right] \cdot [J(\mathbf{U})]^{-1} \cdot \begin{bmatrix} \frac{\partial W'}{\partial \Pi_i} \\ \frac{\partial W''}{\partial \Pi_i} \end{bmatrix} \quad (13)$$

Below are the derivatives included in this formula depending on the variable $\Pi_i \in P_i, Q_i$

$$\begin{aligned} \frac{\partial \Delta P_c}{\partial P_i} &= \frac{U_0}{U_i^2} (B'_i U'_i - B''_i U''_i) - 1, \\ \frac{\partial \Delta P_c}{\partial Q_i} &= \frac{U_0}{U_i^2} (B'_i U''_i + B''_i U'_i) \end{aligned} \quad (14)$$

$$\frac{\partial W'_i}{\partial P_k} = \frac{1}{U_k^2} (R_{ik} U'_k - X_{ik} U''_k), \quad \frac{\partial W''_i}{\partial P_k} = \frac{1}{U_k^2} (X_{ik} U'_k + R_{ik} U''_k),$$

$$\frac{\partial W'_i}{\partial Q_k} = \frac{1}{U_k^2} (X_{ik} U'_k + R_{ik} U''_k), \quad \frac{\partial W''_i}{\partial Q_k} = \frac{1}{U_k^2} (-R_{ik} U'_k + X_{ik} U''_k). \quad (15)$$

Condition for the existence of a derivative $\frac{\partial \Delta P_c}{\partial \Pi_i}$ in (13) will be.

$$\det[J(U)] \neq 0 \quad (16)$$

If the Jacobian NE (nodal equations) is zero at the solution point, then (13) follows $\frac{\partial \Delta P_c}{\partial \Pi_i} = \infty$.

Thus, the limit on the existence of solutions of nonlinear control systems corresponds to the limit mode defined by criterion (1). In other words, if the nodal equations system has a solution for certain values of independent parameters and the Jacobian is different from zero at the solution point, then even with a small change in the parameters, the system will have a well-defined solution. If the Jacobian is equal to or close to zero at the point of solution, then a slight change in the parameters in the direction of weighting the mode will cause the absence of a real solution of the nodal equations.

The formulated criteria for the existence and limit of the established regime are also valid for NE Jacobians written in the form of current balance or power balance.

3. Results and Discussions

The research was carried out on the example of an electrical system, the scheme of which is shown in Fig.1. Weighting was carried out by the active power of the node 12.




Fig. 1. Equivalent diagram of the electrical system of the South-Western MEN (MAIN ELECTRIC NETWORKS).

The results of calculations of the steady-state modes of the electrical system with weighted values of the power of the node 12 are shown in table 1. (ΔP_c ΔQ_c –the total losses of active and reactive Power; U_{12} -the voltage module of the node 12)

Table 1.

P_{12}	ΔP_c	ΔQ_c	U
180	15,706	147,268	215,141
230	20,362	187,478	208,188
280	27,139	245,826	198,534
330	38,705	345,698	182,500
340	42,631	379,795	177,082
341	43,100	383,873	176,435
342	43,588	388,125	175,760
343	44,098	392,571	175,054
344	44,634	397,236	174,314
345	45,198	402,152	173,534
346	45,795	407,361	172,708
347	46,431	412,914	171,827
348	47,114	418,883	170,881

Fig. 2 shows a graph of the dependence of the total loss of active power in the load system of node 12 during weighting.




Figure: 2. A graph of the dependence of the total losses of active power in the load system of node 12 with weighting in the form of row 1

4. Conclusions

1. As can be seen from the graph in Fig.2 the limit mode occurs when $P_{12} = 348 \text{ MBm}$, after which the iterative process diverges. The solution obtained after $P_{12} > 350 \text{ MBm}$, is physically unrealizable because it does not meet the criteria $\frac{\partial \pi}{\partial P_i} > 0$.

2. Thus, the limit normal modes of electrical systems for the power of nodes can be

$$\frac{\partial \Delta P_c}{\partial \Pi_i} = \infty.$$

determined by the criterion

References

1. Automation of dispatch control in electric power systems/ Ed. by Yu.N. Rudenko and V.A.Semenov. - M.: Publishing House MPEI, 2000.
2. Fazylov H.F., Nasyrov T.Kh. Calculations of steady-state modes of electric power systems and their optimization. Tashkent: Moliya, 1999.
3. Nasirov T. H. Fundamentals of the General theory of normal and emergency modes of power systems. - Tashkent: "Fan va texnologiya", 2015. 80 p.
4. Nasirov T.Kh., Gayibov T.Sh. Theoretical foundations of optimization of power system modes. - T.: "Fan va texnologiya", 2014.
5. Methods for optimization of power system modes. V.M. Gornstein, B.P. Miroshnichenko, A.V. Ponomarev and others; Ed. by V.M.Gornstein - M.: Energy, 1981.
6. Arzamastsev D.A. and others. ACS and optimization of power system modes: Textbook for university students / Arzamastsev D.A., Bartolomei P.I., Kholyan A.M. Ed. by D.A. Arzamastsev. M.: Higher. school., 1983.
7. Gayibov T.Sh. Methods and algorithms for power system mode optimization. - T.: Publ. Tashkent State Technical University, 2014.
8. Valdma M, Keel M, Liik O, Tammoja H. Method of Minimax optimization of Power System Operation. Proc. of IEEE Bologna PowerTech 2003, 23-26 June 2003, Bologna, Italy. Paper 252: p. 1-6.